

City of Lynchburg, Pirginia STADIUM PARKING IMPROVEMENTS

STATE	FEDERAL AID		SHEET	
STATE	PROJECT		PROJECT	NO.
VA.		х	OOOO-OOO-OOO SEE TABULATIONS BELOW FOR SECTION NUMBERS	1

FINAL PLANS NOVEMBER 1, 2016

MAYOR	JOAN FOSTER
VICE MAYOR	TRENEY TWEEDY
CITY MANAGER	BONNIE SVRCEK
DIRECTOR OF PUBLIC WORKS	GAYNELLE HART






NOT TO SCALE

	CONTENTS	
SHEET	DESCRIPTION	
1	TITLE SHEET	
1A	SURVEY DATA	
2	GENERAL NOTES	
2A	DETAILS	
2B	RADIAL OFFSET SHEET	
2C	LIGHT POLE DETAILS	
3 THRU 3B	CONSTRUCTION & LIGHTING PLANS	

THIS PROJECT IS TO BE CONSTRUCTED IN ACCORDANCE WITH THE LATEST EDITIONS OF THE CITY OF LYNCHBURG MANUAL OF SPECIFICATIONS & STANDARD DETAILS, THE VIRGINIA DEPARTMENT OF TRANSPORTATION (VDOT) ROAD AND BRIDGE SPECIFICATIONS, THE VDOT ROAD AND BRIDGE STANDARDS, THE VDOT WORK AREA PROTECTION MANUAL, THE VIRGINIA EROSION AND SEDIMENT CONTROL HANDBOOK, AND THE VIRGINIA EROSION AND SEDIMENT CONTROL REGULATIONS. IN THE EVENT OF CONFLICT BETWEEN ANY OF THESE STANDARDS, SPECIFICATIONS OR PLANS, THE MOST STRINGENT SHALL GOVERN.





REVISED

PROJECT MANAGER*William_"Clay" Simmons,P.E.*(434)_455-4443______ SURVEYED BY, DATE *BERKLEY HOWELL & ASSOC., P.C., JL-16-201*L_____ DESIGN BY McCormick_Taylor_lnc.(804-762-5800)_______ SUBSURFACE UTILITY BY, DATE _______

<u>LEGEND</u>

IRON PIN SET

EDGE OF PAVEMENT EDGE OF GRAVEL

WATER LINE LOCATION

SMALL IRRIGATION HEAD LARGE IRRIGATION HEAD TELEPHONE PEDESTAL TELEPHONE MANHOLE

UNDERGROUND TELEPHONE LINE

IP IRON PIPE FOUND R/W RIGHT-OF-WAY

C&G CURB & GUTTER FIRE HYDRANT WATER METER WATER VALVE WATER MANHOLE

EMH ELECTRIC MANHOLE EV ELECTRIC VAULT

ELP ELECTRIC PEDESTAL ET ELECTRIC TRANSFORMER STADIUM LIGHTS LIGHT POLE UTILITY POLE

GUY WIRE

EM ELECTRIC METER

II INVERT IN IO INVERT OUT

DI DROP INLET CB CATCH BASIN

SD STORM DRAIN FD FIELD DRAIN

FENCE

B BOLLARD

SURVEYING WAS PERFORMED TO MAKE THIS DETERMINATION.

8. TOTAL PARKING SPACES - 286 INCLUDING 15 HANDICAP.

SIDE - 8 FEET

PROBLEMS LOCATED WITHIN THE PERIMETER OF THE PROPERTY SHOWN.

0 0 0

EXCEPT AS SHOWN.

UNLESS OTHERWISE NOTED.

6. HORIZONTAL DATUM - NAD 83 VERTICAL DATUM - NGVD 29

BOUNDARY OF THE SURVEYED PROPERTY.

9. BUILDING SET BACKS: FRONT - 30 FEET

CONCRETE GUARDRAIL

TC TERRA COTTA PIPE

OVERHEAD UTILITIES

UNDERGROUND ELECTRIC

SANITARY SEWER CLEAN-OUT SANITARY SEWER LINE

SSMH SANITARY SEWER MANHOLE

STMH STORM SEWER MANHOLE

STORM SEWER LINE

PVC POLYVINYL CHLORIDE PIPE

OUTFIELD FENCE

FIBER OPTIC LINE FOV FIBER OPTIC VAULT GAS LINE GR GAS REGULATOR FP FLAG POLE

SPOT ELEVATION

HANDICAP PARKING SPACE

MAP FOR THE CITY OF LYNCHBURG (#5100930043D) DATED JUNE 3, 2008. NO FIELD


3. THIS PLAT DOES NOT PURPORT TO ADDRESS THE EXISTENCE, DETECTION OR DELINEATION OF ANY ENVIRONMENTALLY SENSITIVE AREAS OR ANY ENVIRONMENTAL

4. THIS PLAT HAS BEEN PREPARED FROM AN ACTUAL FIELD SURVEY DONE AS PER DATE OF THIS PLAT AND THERE ARE NO VISIBLE ENCROACHMENTS OR EASEMENTS


5. THIS TOPOGRAPHIC SURVEY OF CITY STADIUM WAS COMPLETED UNDER THE DIRECT AND RESPONSIBLE CHARGE OF KEVIN A. MERKEY, LS #2217 FROM AN ACTUAL GROUND SURVEY MADE UNDER MY SUPERVISION; THAT THE ORIGINAL DATA WAS OBTAINED ON OCTOBER 24, 2011; AND THAT THIS PLAT MEETS MINIMUM ACCURACY STANDARDS

7. THE RIGHT-OF-WAY/BOUNDARY LINES ALONG WYTHE ROAD AND THE FIRST 442.75 FEET OF NAVAL RESERVE ROAD DO NOT MATCH RECORD INFORMATION IN THE CHAIN OF TITLE, THE LINES SHOWN REPRESENT ENGINEERING DRAWINGS AND ROAD PLANS OF RECORD WITH A FEW MODIFICATIONS TO EXCLUDE ANY ROAD IMPROVEMENTS IN THE

SURVEY ALIGNMENT DATA



DESIGN FEATURES RELATING TO CONSTRUCTION OR TO REGULATION AND CONTROL OF TRAFFIC MAY BE SUBJECT TO CHANGE AS DEEMED NECESSARY BY THE ENGINEER





SHEET NO.

PROJECT MANAGER*William_"Clay" Simmons,P.E.(434) 455-4443_____* SURVEYED BY, DATE *BERKLEY HOWELL & ASSOC, P.C., IL-16-201*L ______ DESIGN BY McCormick_Taylor_lnc.(804-762-5800)_______ SUBSURFACE UTILITY BY, DATE ______

GENERAL NOTES

- 1. Work on this project shall conform to the latest editions of the City of Lynchburg Manual of Specifications & Standard Details, the Virginia Department of Transportation (VDOT) Road and Bridge Specifications, the VDOT Road and Bridge Standards, the VDOT Work Area Protection Manual, the Virginia Erosion and Sediment Control Handbook, and the Virginia Erosion and Sediment Control Regulations. In the event of conflict between any of these standards, specifications or plans, the most stringent shall govern.
- 2. The location of existing utilities as shown is approximate only. The contractor is responsible for locating all public or private utilities that lie in or adjacent to the construction site. The contractor shall be responsible for repairing, at his expense, all existing utilities damaged during construction. Forty-eight (48) hours prior to any excavation call Miss Utility 1 (800) 552-7001.
- 3. The Contractor shall verify all existing features shown on the survey and immediately notify the Engineer of any field conditions that differ from the existing features shown on the plans. Work done by the Contractor after his discovery of such discrepancies shall be done at the Contractor's risk.
- 4. Design features relating to construction or to regulation and control of traffic may be subject to change as deemed necessary by the City of Lyncburg.
- 5. The grade line denotes top of finished pavement unless shown otherwise on typical sections or plans.
- 6. The cost of removal and disposal of all existing items located in the areas to be graded, including, but not limited to the following, shall be included in the price bid for Earthwork: curb, curb & gutter, entrances, sidewalk, inlets, pipe, concrete slabs and foundations.
- 7. The borrow material for this project shall be a minimum CBR 10 or as approved by the Engineer.
- 8. The horizontal location of all drainage structures shown on these plans is approximate only, with the exception of structures showing specific stations, special design bridges and storm sewer systems.
- 9. The horizontal location and invert elevations shown for proposed culverts and storm sewer outfallpipes are based on existing survey data and required design criteria. If during construction, it is found that the horizontal location or invert elevations shown on plans differ significantly from the horizontal location or elevations of the stream or swale in which the culvert or storm sewer outfall pipe is to be placed, the Contractor shall confer with, and get approval from, the Engineer before installing the culvert or storm sewer outfall pipe.
- 10. The "H" dimension shown on plans for drop inlets and junction boxes and the "L.F." dimensions shown for manholes are for estimating purposes and are based on the proposed invert elevations shown for the structure and the anticipated top (rim) elevation based on existing or proposed finished grade. The actual "H" or "L.F." dimensions are to be determined by the contractor from field conditions.
- 11. All pipe on this project shall be concrete. For strength, sheet thickness, or class designation; available sizes; height of cover limitations; and other restrictions for a particular pipe type or height cover, see applicable sections of the VDOT Road and Bridge Standards PC-1.
- 12. Where open joint pipe is to be used, no joint shall be opened a distance exceeding 25% of the spigot length. Sealing of the pipe joint shall be in accordance with Section 302 of the applicable VDOT Road and Bridge Specifications.
- 13. A pipe joint length different from that stated on the plans may be used. An adjustment in the percentage of open joint (not to exceed 25% of the spigot length) or amount of bevel shall be made that will obtain the radius stated on the plans. Extra payment for this adjustment will not be allowed. The proposed adjustment shall be approved by the Engineer prior to installation of the pipe line.
- 14. The proposed riprap may be omitted by the Engineer if the slope designated for placement of riprap is found to be comprised of solid rock or closely consolidated boulders with soundness, size and weight equal to, or exceeding, the specifications for proposed riprap.
- 15. All existing drainage facilities labeled "To Be Abandoned" shall be left in place, backfilled and plugged in accordance with the VDOT Road and Bridge Standard PP-1. The cost incidental to this and the Flowable Backfill shall be included in the contract price for other items.
- 16. Existing drainage facilities being utilized as a part of the drainage system, and designated on the plans "To Be Cleaned Out" shall be cleaned as directed by the Engineer. The cost incidental to this shall be included in the contract price for other items.

- 17. Proposed drop inlets with a height (H) less than the standard minimum shown in the VDOT Road and Bridge Standards shallbe considered and paid for as Standard Drop Inlets for the type specified.
- 18. All pavement, stone, base, and saw cut required to install the new curbing shall be paid as incidental to the curb cost.
- 19. Clearing and grubbing shall be confined to those areas needed for construction. No trees or shrubs in ungraded areas shallbe cut without the permission of the Engineer.
- 20. All pavement markings and traffic flow arrows shown on the roadway construction plans are schematic only. The actual location and application of pavement markings shall be in accordance with Section 704 of the applicable VDOT Road and Bridge Specifications, MUTCD, sequence of construction/traffic control plans, pavement marking on plan Sheet 8 and as directed by the Engineer.
- 21. The following sources, under contract with the City of Lynchburg, have provided information on this project:

Hydraulic Design - EPR, P.C.

Roadway Design - McCormick Taylor, Inc.

Utility Design - N/A

Utility Designation - MISS UTILITY and City

Survey - Berkley-Howell & Associates, and P.C. Perkins & Orrison, Inc.

If questions or problems arise during construction, please contact the City of Lynchburg attn: Clay Simmons DPWD 434-455-4450. DO NOT CONTACT THE OUTŠIDE SOURCES.

- 22. The temporary erosion and siltation control items shown on the plans are intended to provide a general plan for controlling erosion and siltation within the project limits. The Erosion & Sediment Control (ESC) Plan is based on field conditions at the time of plan development and an assumed sequence of construction for the project. The contractor, in conjunction with the Project Engineer and/or Environmental Monitor, shall adjust the location, quantity and type of erosion and sediment controlitems required based on the actual field conditions encountered at the time of construction and the actual scheduling and sequencing of the construction activities. Significant changes to the proposed ESC Plan (e.g., those that require emergengy analysis) shall be submitted to the City of Lynchburg for review and approval. Any changes to the proposed ESC Plan must be noted on a designated plan set (Record Set) which shall be retained on the project site and made available upon request.
- 23. The areas beyond the project's construction area are to be protected from siltation in accordance with the Virginia Erosion and Sediment Control Handbook. Perimeter controls such as filter barrier, silt fence, diversion dikes, turbidity curtains, etc. shall be installed prior to any grubbing operations or other earth moving activities.
- 24. Rock for Check Dams, Drop Inlet Silt Traps, Erosion Control Stone and Riprap shall be in accordance with Section 203 and Section 414 of the applicable VDOT Road and Bridge Specifications.
- 25. All disturbed areas shall be fertilized and seeded with the applications as follows until a suitable stand of grass is obtained and approved by the Engineer.

Fertilizer (10-10-10) © 1000 lb/acre or Approved Equivalent

Ground Limestone © 1 ton/acre

Grass Seed (Ky. 31 Fescue) © 150 lb/acre

Mulch (Straw or Approved Equivalent) @ 400 lb/acre If construction takes place between November 1 and April 1, an additional

150 lb/acre of Rye grass is required.

- 26. Items depectided as NIC are not included in Contract.
- 27. All seeded and landscaped areas shall be watered with a minimum of 1/2 rainfall equivalent every 3 days from installation until first hard freeze. This water will be supplied and paid for by the contractor and should be included in the bid item for the individual seed and landscape items if bid separately or in the mobilization item if bid lump sum.
- 28. All seeding and landscaping will be guaranteed by the contractor from 1 year of installation.
- 29. All old lighting poles, bases, and wiring that is being replaced by new lighting shall be demoed and removed by contractor with the cost being incidental to the pole bases and conduit.

REVISED	CTATE		STATE	SHEET NO.
	STATE	ROUTE	PROJECT	SHEET NO.
	VA.		STADIUM PARKING : IMPROVEMENTS :	2


DESIGN FEATURES RELATING TO CONSTRUCTION OR TO REGULATION AND CONTROL OF TRAFFIC MAY BE SUBJECT TO CHANGE AS DEEMED NECESSARY BY THE ENGINEER

30. All pavement, base, sidewalks, and other items impacted by the installation of the lighting poles, bases, and wiring be replaced in kind or better by contractor with the cost being incidental to the pole bases and conduit.

Plotted By: localuser

PROJECT MANAGER*William_"Clay" Simmons,P.E.(434)_455-4443_*SURVEYED BY, DATE *BERKLEY_HOWELL_&_ASSOC.,P.C.,JL-16-201L______*DESIGN BY *McCormick_Taylor_lnc.(804-762-5800)______*SUBSURFACE UTILITY BY, DATE_______

DETAILS




STANDARD 6" CURB


VIRGINIA DEPARTMENT OF TRANSPORTATION

ACCEPTABLE ALTERNATIVE
IF CURB IS EXTRUDED

SPECIFICATION REFERENCE



DESIGN FEATURES RELATING TO CONSTRUCTION
OR TO REGULATION AND CONTROL OF TRAFFIC
MAY BE SUBJECT TO CHANGE AS DEEMED
NECESSARY BY THE ENGINEER



NOTES:

 $\langle 2 \rangle$

PATCH DEPTH

1. PAVEMENT SHALL BE AS SHOWN UNLESS OTHERWISE SPECIFIED.

8" BM25

7" VDOT NO.21A

TOTAL = 17"

I ATL	THE CITY OF LYNCHE	BURG		
	TRENCH PATCH	SCALE: NOT TO SCALE	DETAIL # 25.18	
BIR	ASPHALT STREETS — TYPE A,B,& C USE WITH THE CITY OF LYNCHBURG STANDARD SPECIFICATIONS ONLY	REVISION DATE: 12-12-2014	SHEET #: 1OF1	


6" BM25

4" VDOT NO.21A 4" VDOT NO.21A

TOTAL = 12" TOTAL = 10"

4" BM25

SHEET NO.



POINT	NORTHING	EASTING	RADIUS (FT)	CURVE LENGTH (FT)	POINT	NORTHING	EASTING	RADIUS (FT)	CURVE LENGTH (FT)
1	3666881.952	11289327.32	5.0	11.2	51	3666863.591	11289616.85	1.0	2.8
2	3666890.485	11289330.12	5.0	11.2	52	3666835.922	11289620.69	2.0	3.1
3	3666891.479	11289337.28	1.5	2.4	53	3666864.179	11289618.73	1.0	2.8
4	3666890.2	11289338.98	1.5	2.4	54	3666834.216	11289622.95	2.0	3.1
5	3666858.284	11289351.59	0.5	1.2	55	3666835.054	11289628.98	3.0	5.7
6	3666858.711	11289352.43	0.5	1.2	56	3666839.377	11289631.25	3.0	5.7
7	3666924.604	11289579.53	0.5	0.8	57	3666830.044	11289662.28	15.0	19.7
8	3666925.168	11289579.96	0.5	0.8	58	3666842.033	11289656.23	15.0	26.2
9	3666925.714	11289583.89	5.0	6.2	59	3666883.048	11289635.51	5.0	7.0
10	3666923.014	11289589.04	5.0	6.2	60	3666880.515	11289641.41	5.0	7.0
11	3666891.174	11289593.26	0.5	0.8	61	3666822.138	11289678.8	15.0	19.7
12	3666890.748	11289593.82	0.5	0.8	62	3666863.16	11289665.29	15.0	26.2
13	3666891.278	11289597.64	5.0	9.5	63	3666864.087	11289668.37	5.0	7.9
14	3666898.483	11289601.42	5.0	9.5	64	3666860.74	11289674.6	5.0	7.9
15	3666949.098	11289602.14	5.0	7.4	65	3666893.407	11289684.25	3.5	6.1
16	3666898.785	11289627.56	3.8	11.7	66	3666898.308	11289686.38	3.5	6.1
17	3666926.43	11289613.52	3.8	11.7	67	3666882.45	11289790.25	1.5	2.4
18	3666902.183	11289634.28	3.8	11.7	68	3666881.481	11289792.11	1.5	2.4
19	3666955.568	11289603.92	5.0	7.4	69	3666891.17	11289787.62	3.0	8.2
20	3666929.939	11289620.14	3.8	11.7	70	3666893.982	11289792.78	3.0	8.2
21	3667065.992	11289744.22	3.0	6.5	71	3666884.264	11289798.73	1.5	2.7
22	3667054.697	11289755.51	1.5	2.3	72	3666886.544	11289799.13	1.5	2.7
23	3667066.48	11289749.49	3.0	6.5	73	3666967.946	11289826.27	4.9	15.5
24	3667056.757	11289755.91	1.5	2.3	74	3666973.199	11289834.58	4.9	15.5
25	3667015.976	11289790.05	4.4	14.6	75	3667013.769	11289928.01	4.4	14.6
26	3666990.741	11289811.82	4.6	13.8	76	3667019.719	11289934.59	4.4	14.6
27	3667020.613	11289797.6	4.4	14.6	77	3667045.834	11289914.26	4.9	15.5
28	3666995.624	11289819.52	4.6	13.8	78	3667053.432	11289920.51	4.9	15.5
29	3667062.941	11289893.39	4.6	13.8	79	3667040.712	11289950.42	3.0	6.1
30	3667083.856	11289867.87	4.4	14.6	80	3667045.608	11289951.79	3.0	6.1
31	3667069.994	11289899.17	4.6	13.8	81	3667047.804	11289959.24	15.5	17.0
32	3667090.721	11289873.48	4.4	14.6	82	3667043.594	11289974.88	15.5	17.0
33	3667126.422	11289815.94	4.4	14.6	83	3667062.08	11289986.32	20.0	14.3
34	3667133.123	11289821.74	4.4	14.6	84	3667086.462	11289991.44	12.5	16.2
35	3667261.036	11289955.6	1.5	3.3	85	3667086.323	11289993.08	3.0	1.7
36	3667263.496	11289956.66	1.5	3.3	86	3667201.575	11290000.7	3.0	8.4
37	3667269.675	11289948.87	5.0	4.7	87	3667213.274	11289976.03	4.5	14.1
38	3667267.892	11289952.99	5.0	4.7	88	3667206.414	11290004.1	3.0	8.4
39	3667313.254	11289879.09	4.4	14.6	89	3667211.326	11289999.15	15.0	5.1
40	3667338.078	11289830.08	4.4	14.6	90	3667214.234	11289995.01	15.0	5.1
41	3667322.118	11289879.31	4.4	14.6	91	3667221.406	11289979.89	4.5	14.1
42	3667346.917	11289829.38	4.4	14.6	92	3667183.099	11290063.34	1.5	2.3
43	3667343.82	11289922.29	3.0	9.4	93	3667183.517	11290065.38	1.5	2.3
44	3667348.421	11289918.44	3.0	9.4	94	3667189.767	11290052.82	3.0	5.6
 45	3666829.014	11289382.32	5.0	11.2	95	3667194.602	11290052.5	3.0	5.6
46	3666837.546	11289385.13	5.0	11.2	96	3667202.597	11290062.06	1.5	2.3
47	3666838.454	11289391.67	1.5	2.4	97	3667202.451	11290064.13	1.5	2.3
48	3666837.174	11289393.36	1.5	2.4		1		1	
49	3666806.066	11289405.86	0.5	1.2					
	2000000.000	11200-100.00	0.6	1.2					

3666806.493

11289406.7

	REVISED	STATE		STATE	SHEET NO	
		SIAIE	ROUTE	PROJECT	JIIEEI IN	
		VA.		STADIUM PARKING IMPROVEMENTS	2B	


DESIGN FEATURES RELATING TO CONSTRUCTION OR TO REGULATION AND CONTROL OF TRAFFIC MAY BE SUBJECT TO CHANGE AS DEEMED NECESSARY BY THE ENGINEER


PROJECT MANAGER*William_"Clay" Simmons, P.E.(434) 455-4443_____* SURVEYED BY, DATE *BERKLEY HOWELL* & *ASSOC, P.C.,JL-16-201*L______ DESIGN BY McCormick_Taylor_lnc.(804-762-5800)________ SUBSURFACE UTILITY BY, DATE ______

DETAILS



DESIGN FEATURES RELATING TO CONSTRUCTION OR TO REGULATION AND CONTROL OF TRAFFIC MAY BE SUBJECT TO CHANGE AS DEEMED NECESSARY BY THE ENGINEER






FEATURES & SPECIFICATIONS CONSTRUCTION - Welds conform to applicable AWS structural welding code Pole shaft is one piece, low carbon alloy steel per ASTM A595, Grade A or ASTM A500, Grade C with 50,000-PSI minimum yield strength. Pole base shall be per ASTM A36 and shall telescope pole shaft and be circumferentially welded top and bottom. Hand hole is 2" x 4" minimum, cover and fasteners are included. Base covers shall be

two piece, interlocking construction. Finish shall match pole. Removable pole cap shall be provided with each drill pattern type pole. Non-structural fasteners shall be stainless FINISH - Galvanized poles per ASTM A123. Painted poles shall be semi-gloss powder paint.

GROUNDING – Grounding provision shall be immediately accessible through hand hole, ½-13 threads.

ANCHOR BOLTS – Steel anchor bolts shall be per AASHTO M314 or ASTM F 1554 - Grade 55, hot dip galvanize. Nuts and washers shall be per AASHTO M314-90 or ASTM F 1554 – hot dip galvanized.





POLE ORDERING DATA
How to construct a catalog number for SSS poles:
EXAMPLE SSS2555C D1 R3 BZ 1 Fill in Catalog Numl
4 2 2 4 5

STEP	CATALOG	DESCRIPTION			
	NUMBER				
1. BASE POLE	(SEE SHEET 2)	SQUARE STRAIGHT STEEL			
2. POLE TOP STYLE	D2 DRILL D3 DRILL D4 DRILL D5 DRILL P2 TENO P3 TENO P4 TENO	ING FOR 1 UNIT ING FOR 2 UNITS @ 180 ING FOR 3 UNITS @ 90 ING FOR 4 UNITS @ 90 ING FOR 2 UNITS @ 90 ING FOR 2 UNITS @ 90 N, 2.38 O.D. X4" LG. N, 4.00 O.D. X6" LG. N, 2.88 O.D. X4' LG.	4 . FINISH	BK BZ GN GR HG PP W H	BLACK PAINT BRONZE PAINT GREEN PAINT GRAY PAINT HOT DIP GALVANIZED PRIME PAINT WHITE PAINT
3. POLE TOP DRILL PATTERN	H3 PARK J4 MIRR R2 MOD 6 R3 MON 6 T3 POLE: W5 PARK ND NO DF AF1 AEL 5 AF2 AEL 1 AF5 AEL A	53	5 . OPTION	S 1 3	FESTOON BOX TAMPER RESISTANT SCREWS VIBRATION DAMPENER

1. Pole top drill pattern types H1 - W5 are available on drilled pole tops only. ND is only available on tenon pole tops. 2. The Festoon Box is located on the same side as the hand hole, 36" above pole base. Receptacle / Cover are not included.

HOLOPHANE SSS.PMD (HL-2079) 5/29/13





BC								
	-			Min.				
		Ref.	Bolt	Base	Base			Bolt
		Item	Circle	Size	Thk.	Bolt	Anchor	Circle
202		No.	Dia.	"D"	"T"	Projection	Bolt Set	Template
- "D"	SQ:	3	11	11	1	3.50 - 4.00	AB-26-4	TMP-45

LIGHTING PLAN GENERAL NOTES & QUANTITIES

- 1. Aep Will Provide And Install All Light Poles, Luminaires And Conductor Cable. Contractor Shall Provide And Install All Remaining Items Such As Pole Foundations,
- 2. The Contractor Shall Field Verify Anchor Bolts And Patterns And Foundations With Aep Prior To Installing Lighting Pole Foundations.
- 3. All Luminaires Shall Be Fused In The Transformer Base, Handhole, Fusebox, Or Nearest Junction Box By Aep.

Junction Boxes And Conduits.

- 4. Conduits And Junction Boxes Shown On These Plans Are Diagrammatic And Actual Conduit Runs And Junction Box Locations Shall Conform To The Field Conditions.
- 5. Certain Utilities Within The Vicinity Of This Project Area Are Shown On The Plans. The Utilities Shown Are Not Guaranteed To Be Complete Or Accurately Located. The Contractor is Responsible For Locating All Existing Utilities And Lighting Systems Before Proceeding With Work.
- 6. At Locations Where Proposed Conduit Shall Cross Existing Conduit, The Contractor Shall Hand Dig The Trench And Shall Take Adequate Care Not To Damage The Existing Conduit Or The Contents Thereof. These Conditions Shall Apply At All Such Conduit Crossings Except Those Locations Where Proposed Conduit Will Cross Conduit Designated To Be Abandoned.
- 7. Conduit Shall Be Installed With Large Radius Offsets (5' Minimum Radius) To Bypass Drainage Inlets, Manholes, And Other Obstructions.
- 8. The Location Of The Light Pole Foundation Grounding Rod Shall Be Marked On The Top Surface Of The Foundation By A Recessed Arrow And Initial "G" Formed In The Concrete. The Ground Rod Shall Typically Be Placed To The Left Of The Lighting Pole Foundation As Observed From The Pole Handhole.
- 9. Conductors In Junction Boxes, Manholes, And All Equipment Enclosures Shall Be Neatly Arranged And Laced With Approved Cable Ties.
- 10. Where Conductor Cables Terminate In Junction Boxes Or Lighting Standards, They Shall Be Tested And Capped With 3 Ft. Of Slack Per Conductor.
- 11. Locations Of Existing Junctions Boxes And Manholes Shown On The Plans Are Approximate.
- 12. Areas Around Cabinets, Junction Boxes And Manholes On Slopes Shall Be Graded As Approved By The Engineer.
- 13. The Contractor Shall Coordinate Electrical Service With The Engineer And With Aep.
- 14. All Underground Conduits Shall Be Sloped To Drain Junction Boxes Or Manholes. If This Cannot Be Accomplished, They Shall Be Provide With Drainage Tees At The Low Points Of Conduits.
- 15. All Junction Boxes And Manholes Shall Be Provided With A Means For Drainage.

SHEET NO.

2:C

